

ADB		Room Data Sheet		Y0330-PCCI	
Project:	PCCI-ALL	PCCI Exemplar Rooms			
Department:	PCCI	All PCCI Exemplar Rooms			
Room:	Y0330-PCCI	Dirty utility, sluice, disposal			
Room Number:				Revision Date:	22/01/2008
Activities:	1) For room / space activities, see notes section				
Personnel:	1 - 2 Staff				
Planning Relationships:	Adjacent to main corridor.				
Space Data:	Area (m²):	10.00	Height (mm):	2,700	
	Room height is a minimum.				
Notes:	<p>Activities:</p> <ul style="list-style-type: none"> - Disposal of liquid waste. - Cleansing trays, trolleys and equipment. - Holding 'SHARPS' in containers for collection/disposal. - Bagging and holding materials and equipment prior to transfer to the disposal point. - Holding contaminated linen and clothing prior to transfer to the dirty linen hold. - Holding supply of colour-coded disposal bags. - Clinical hand washing. <p>Notes:</p> <ul style="list-style-type: none"> - Waste disposal in accordance with Whole Hospital Waste Disposal Policy. <p>Revisions;</p> <p>10-10-07 Issue for M&E review</p> <p>23-11-07, M&E Incorporated and prepared for final issue.</p> <p>22-01-08, Exemplar Issue</p>				

ADB	Room Environmental Data	Y0330-PCCI
------------	--------------------------------	-------------------

Project:	PCCI-ALL	PCCI Exemplar Rooms
Department:	PCCI	All PCCI Exemplar Rooms
Room:	Y0330-PCCI	Dirty utility, sluice, disposal
Room Number:	Revision Date: 22/01/2008	

AIR	Requirements	Notes
Winter Temperature (DegC):	20	Max summer temperature not to be exceeded for more than 120hrs per annum. Mechanical ventilation (supply) may be required to suit location - mixed mode necessary
Summer Temperature (DegC):	26	
Mechanical Ventilation (Supply ac/hr):	10.0	
Mechanical Ventilation (Extract ac/hr):		
Pressure Relative to Adjoining Space:		
Filtration (%DSE and % Arrestance):		
Humidity (%RH):	-ve	
	/	

General Notes:

LIGHTING		
Service Illumination (Lux):	300	Working plane
Service Illumination Night (Lux):		
Local Illumination (Lux):		
Colour Rendering Required:	Y	Lighting of the level and quality one third to one half that provided by normal lighting
Standby Lighting Grade:	B	

General Notes:	Intelligent lighting control system enabling daylight dimming and maintained illumination levels. PIR sensing control with manual override. Indirect/direct lighting to be adopted.
-----------------------	---

NOISE		
Privacy Factor Required (dB):		Ref HTM08-01 Privacy Factor: Table 3 &4 Mechanical Services: Table 2 Intrusive noise: Table 1 Derogation applicable where natural ventilation is incorporated, site assessment of background noise levels required.
Mechanical Services (NR):		
Intrusive Noise (NR Leq):		
*Acceptable Sound Level [L10dB(A)]:		
*Speech Privacy Required:	N	
*Quality Which Cannot Be Tolerated:		
(* alternative format)		

General Notes:

SAFETY		
Hot Surface Max. Temp (DegC):	82	Sign required: 'Caution Very hot Water' above the sink. Hot Water Max.Temp: Washbasin 41.
Hot Water Max. Temp (DegC):	60	

General Notes:

FIRE
Enclosure:

Automatic Detection:

Heat

ADB	Room Design Character		Y0330-PCCI
Project:	PCCI-ALL	PCCI Exemplar Rooms	
Department:	PCCI	All PCCI Exemplar Rooms	
Room:	Y0330-PCCI	Dirty utility, sluice, disposal	
Room Number:		Revision Date:	22/01/2008
Walls:	Surface Finish (HTM 56): 3 i.e. Impervious, jointless, smooth Moisture Resistance (HTM 56): N i.e. Normal humidity.		
Floor:	Surface Finish (HTM 61): 4: Hard, impervious, jointless, extra slip resistance		
Ceiling:	Surface Finish (HTM 60): 3: Smooth, imperforate Moisture Resistance (HTM 60): N: Normal humidity.		
Doorsets:	(See also HTM 58) Size (Single, Leaf & Half, Double. [mm]): 1x 1000mm, single leaf Access Requirements: Person/Equipment access. Vision Panel (clear/obscured, privacy control, high/low level): None. Finish (wipe down / standard): Standard. Lockable Requirements (Not, Standard, Keypad, Proximity Sensor): Standard Lockable, retention, self closing, delayed action Special Requirements (Radiation Protection etc.): Pest-proof Special Signage: None		
Windows:	(HTM 55) Obscured.		
Internal Glazing:	(HTM 57) N/A		
Hatch:	N/A		
Notes:			

ADB	Schedule of Components by Room	Y0330-PCCI
------------	---------------------------------------	-------------------

Project:	PCCI-ALL	PCCI Exemplar Rooms
Department:	PCCI	All PCCI Exemplar Rooms
Room:	Y0330-PCCI	Dirty utility, sluice, disposal
Room Number:	Revision Date: 22/01/2008	

Quantity			Code	Description	Alt. Code	Grp
New	Trans	Total				
1		1	CAL020	LAMP repeat staff emergency call, wall mounted		1
1		1	DSU006	DISPOSAL UNIT, plain top, sink & hopper with flushing rim, 100mm outlet, no tapholes no overflow, concealed cistern, stainless steel, left hand, 1600W 650D		1
1		1	MSC182	CABINET base, 600mm facing, with 2 shelves, 1 door hinged right, on plinth, o/a height 900, HTM71		1
1		1	MSC183	CABINET base, 600mm facing, with 2 shelves, 1 door hinged left, on plinth, o/a height 900, HTM71		1
1		1	MSW002	WORKTOP, for 2x 600mm facing inserts cabinets, 1310W 500D nominal, HTM71		1
1		1	OUT005	SOCKET outlet switched 13amp single, wall mounted		1
1		1	SHE221	SHELF, 1200W 300D		1
1		1	SHE222	SHELF, 1200x400		1
1		1	TAP809	TAP bib 12mm, lever action, cold water connection, HTM64TBH1		1
1		1	TAP810	TAP bib 12mm, lever action, hot water connection, HTM64TBH1		1
1		1	TAP892	TAP, bib, 2x8 mm thermostatic mixer, automatic action, sensor operated non-touch. HTM64TBH6		1
1		1	WAS103	WASTE, recessed, grated, metal, 38mm, with plug & chain, HTM64		1
1		1	WAS107	TRAP, bottle, 32mm, HTM64		1
1		1	WAS108	TRAP, bottle, 38mm, HTM64		1
1		1	WAS110	BASIN, medium, hospital pattern, vitreous china, no tap holes, no overflow, concealed waste, 500W 400D, HTM64LBH/M		1
1		1	BOA034	BOARD, marker, whiteboard, dry-wipe, with pen holder, wall mounted, 600H 900W		2
1		1	DIS007	DISPENSER, paper towel roll, wall mounted		2
1		1	DIS011	DISPENSER, barrier cream, disposable single cartridge, wall mounted		2
1		1	DIS013	DISPENSER, paper towel, wall mounted		2
1		1	DIS030	DISPENSER, soap, lever action, wall mounted		2
1		1	DIS904	DISPENSER, disposable gloves, set of 3, and apron, wall mounted		2
6		6	HOL006	HOLDER, sack, with lid foot operated, medium, freestanding, 875H 432W 385D		3